



REVISIONS				APPROVALS
DESCRIPTION	BY	DATE	APPROVED	
UPDATE AND RENAME	DV	07/20/21		
2022 CODE UPDATE	DV	01/01/23		

HOSE RESTRICTIONS



ACCESS ROADWAY



ACCESS ROADWAY

FIRE ACCESS ROADWAYS

1. THESE STANDARDS PERTAIN TO THE MINIMUM FIRE DEPARTMENT ACCESS REQUIREMENTS. CITY ROADWAY STANDARDS MAY REQUIRE DIFFERENT SPECIFICATIONS WHEN APPROPRIATE.
2. THE ACCESS ROADWAY SHALL BE EXTENDED TO WITHIN 150' OF ALL PORTIONS OF THE EXTERIOR WALLS OF THE FIRST STORY OF ANY BUILDING (SEE HOSE RESTRICTIONS ABOVE).
3. THE DIMENSION OF 150' CAN BE INCREASED WHEN THE BUILDING IS EQUIPED THROUGHOUT WITH AN APPROVED AUTOMATIC FIRE SPRINKLER SYSTEM

DRAWN BY: MRW	CITY OF ATASCADERO FIRE AND EMERGENCY SERVICES	DRAWING NO.
DESIGNED BY SBK	HOSE RESTRICTIONS AND FIRE ACCESS ROADS	F-3
DATE: 09/06/2006		
FILE NAME: F-3.2023.PDF		