




CITY OF ATASCADERO

BUSINESS LICENSE INSPECTION REPORT

PHONE: 805-461-5000 * EMAIL: PERMITCENTER@ATASCADERO.ORG

1. A City of Atascadero business license is required to legally operate and conduct business within city limits.
2. Street addresses are required to be displayed at a minimum of five inches (5") in height and are visually contrasting to the surface attached.
3. Emergency response access
4. Comments on obvious visual concerns on the building's exterior condition.
5. Smoke detection equipment
6. Alarm systems
7. Fire sprinkler systems
8. Kitchen hood and suppression system
9. A minimum 36" wide, clear path is required to exterior exits.
10. Fire extinguishers are to be mounted by NFPA or equivalent hangers.



11. Comments on obvious visual concerns of the mechanical system and its condition.
12. The electrical inspection will include pointing out any obvious electrical concerns. The inspector will require access to the sub panel supplying the business with power and means of disconnect. A clear space of 30" wide and 36" deep is required in front of all electrical panels and disconnects. The use of extension cords is not permitted.
13. Excessive debris inside structures may create fire hazards. Clear paths of travel throughout the space is required. Installation of storage racks and shelves may require building permits with approved anchorage details to prevent displacement in a seismic event.
14. High pile storage requires a plan review with approval and issuance of a building permit for inspection. Approved rack installation requires a minimum of 18" clearance from the fire sprinkler head to the stored articles.
15. Barrier removal
16. Building permits are required for the modifications that have been made and/or are proposed.